

Certificate of Conformity

Number: C211-0018/20 **Project file:** C20201064

Product: Installation conduits

Type reference: CS16, CS20, CS25, CS32, CS40, CS50

Trademark: RATKOM

Applicant: RATKOM d.o.o.,
Đački put 21, Oriž, HR-21315 Dugi Rat, Croatia

Manufacturer: RATKOM d.o.o.,
Đački put 21, Oriž, HR-21315 Dugi Rat, Croatia

Place of manufacture: RATKOM d.o.o.,
Đački put 21, Oriž, HR-21315 Dugi Rat, Croatia

This certificate is granted subject to the SIQ's rules on product certification. SIQ certifies the conformity of the products with the requirements of the listed standards.

Ratings: See page 2

Standard: EN 61386-22:2004 + A11:2011,
EN 61386-1:2008

Test report: T211-0349/20 (2020-06-02)

Remarks: This certificate shall apply to the products identical to the tested sample and shall remain valid for the period of 3 years until 2023-06-02 or until the validity date of the listed standards, whichever occurs earlier.

Date: 2020-06-02

Authorized signature: Bojan Pečavar



Only integral publication of this certificate is allowed. This certificate may only be reproduced in its entirety and without any changes. On request SIQ will give information about the validity of the certificate.

Certificate of Conformity

Number: C211-0018/20

Ratings:

Type	Color	Resistance to compression	Resistance to impact	Lower temperature range	Upper temperature range
CS 16	Orange	2	2	3	1
CS 20	Orange	2	2	3	1
CS 25	Orange	2	2	3	1
CS 32	Orange	2	2	3	1
CS 40	Orange	2	2	3	1
CS 50	Orange	2	2	3	1

Date: 2020-06-02

Authorized signature: Bojan Pečavar

